




NOVAPRODUCTS
GLOBAL

LIFELONG SOLUTIONS FOR LONG LIFE BUILDINGS
www.novaproducts.com.au

CCRG10 Premium with Lion Insert



Aggregate

The highest grade aggregates with Mohs' rating of 9 for maximum anti-slip capability and long life.

Tested to AS/NZS Standards

Tested and certified to AS/NZS 4586:2004 *Slip resistance classification of new pedestrian surface materials.*

Test Date:	November 2004	
Test Number:	04/6376.1 to 7.	
	Test Equipment used:	
Wet Testing:	Stanley Skid Resistance Tester (Pendulum) Serial Number: 0320 Calibrated 20/5/03.	
Dry Testing:	Tortus Floor Friction Tester, Tortus Model MK2 (with integral printer), Serial Number: 154	
Test Standard:	AS/NZS 4586-1999 slip resistance classification of new pedestrian surface materials.	
	WET Mean (5 specimens)	DRY Mean (2 runs)
Industrial Grade 1	67	0.975
Industrial Grade 2	76	1.065
Offshore Grade	66	0.905
Classification	V	F